



# 产品认证证书

证书编号: CQC16002150253

## 申请人名称及地址

浙江力夫自控技术股份有限公司  
浙江省乐清市乐清经济开发区纬十五路 220 号

## 制造商名称及地址

浙江力夫自控技术股份有限公司  
浙江省乐清市乐清经济开发区纬十五路 220 号

## 生产企业名称及地址

浙江力夫自控技术股份有限公司 (V024450)  
浙江省乐清市乐清经济开发区纬十五路 220 号

## 产品名称和系列、规格、型号

### 压力开关

LF08 系列 (系列命名方式见附件) 250VAC 3A 断开压力值: 0.02MPa-4.5MPa 接通压力值: 0.02MPa-6.5MPa 压力介质: 气体/液体 1.C 型 自动动作 10000 周期 PT1175 插片端子 引线连接 IP00 污染等级 2

## 产品标准和技术要求

GB/T 14536.1-2008; GB/T 14536.7-2010

## 认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-448321-2016 认证规则的要求, 特发此证。

发证日期: 2020 年 07 月 30 日

本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016 年 08 月 15 日

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



# 产品认证证书

附 录

证书编号：CQC16002150253

第 1 页 共 1 页

纸 号：

系列命名方式：

LF08-A/B



- 1、产品主型号：接口为钢管、不锈钢管或螺纹式接头的压力控制器统称为 LF08 系列。
- 2、接通压力值：压力控制器动作接通时的压力参数。
- 3、断开压力值：压力控制器动作断开时的压力参数。

注：此附录与证书同时使用时有效。

主任：\_\_\_\_\_

陆梅

## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC16002150253

## NAME AND ADDRESS OF THE APPLICANT

ZHEJIANG LEFOO CONTROLS CO.,LTD.

No.220,Weishiwu Road, Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

ZHEJIANG LEFOO CONTROLS CO.,LTD.

No.220,Weishiwu Road, Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.China

## NAME AND ADDRESS OF THE FACTORY

ZHEJIANG LEFOO CONTROLS CO.,LTD. (V024450)

No.220,Weishiwu Road, Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

Pressure Switch

LF08 系列（系列命名方式见附件） 250VAC 3A 断开压力值：0.02MPa-4.5MPa 接通压力值：  
0.02MPa-6.5MPa 压力介质：气体/液体 1.C 型 自动动作 10000 周期 PT1175 插片端子 引线连  
接 IP00 污染等级 2

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14536.1-2008;GB/T 14536.7-2010

## TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-448321-2016 .

Valid from: Jul.30,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

Date of original issued: Aug.15,2016

President: \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>



# PRODUCT CERTIFICATE


APPENDIX

Page 1 of 1

CERTIFICATE NO.: CQC16002150253

PAPER:

系列命名方式:



- 1、产品主型号：接口为钢管、不锈钢管或螺纹式接头的压力控制器统称为 LF08 系列。
- 2、接通压力值：压力控制器动作接通时的压力参数。
- 3、断开压力值：压力控制器动作断开时的压力参数。

NOTE: This appendix is valid when used with the certificate.

President: \_\_\_\_\_

Lu Mei

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>