



Product Service

Attestation of Conformity

No. N8A 111343 0009 Rev. 00

Holder of Certificate: **Zhejiang Lefoo Controls Co., Ltd**
No.220,Weishiwu Road.Economic Development Zone
325600 Yueqing, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: **Pressure switches**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 874102213908-00

Date, 2022-11-17

(Jie Zhu)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 111343 0009 Rev. 00

Model(s): LF08-1, LF08-2, LF08D-1, LF08D-2, LF08H-1, LF08H-2

Parameters:

Rated voltage: See table 1
 Rated frequency: 50/60Hz
 Rated current: See table 1
 Features of automatic action: Type 1.B
 Degree of protection: IP00
 Degree of pollution: 2
 Ambient temperature limit of the switch head: 35T90
 Circuit disconnection: Micro-disconnection
 Number of cycles of automatic action: See table 1
 Operating pressure: See table 1

Table 1

Model	Rated voltage	Rated current	Number of cycles of automatic action:	Operating pressure:
LF08-1, LF08-2	250VAC, 120VAC	6A	50 000	Max. 6.5MPa
LF08D-1, LF08D-2	250VAC, 120VAC	15A	30 000	Max. 1.4MPa
LF08H-1, LF08H-2	250VAC, 120VAC	6A	30 000	Max. 6.5MPa

Tested according to: EN 60730-1:2016/A2:2022
EN 60730-2-6:2016/A1:2020