



Product Service

Attestation of Conformity

No. N8A 111343 0003 Rev. 00

Holder of Certificate: **Zhejiang Lefoo Controls Co., Ltd**
 No.220, Weishiwu Road. Economic Development Zone
 325600 Yueqing, Zhejiang
 PEOPLE'S REPUBLIC OF CHINA

Product: **Pressure switches**
Model(s): **LF16**

Parameters:

Rated voltage:	240VAC, 120VAC
Rated frequency:	50/60Hz
Rated current:	20A for 120VAC, 12A for 240VAC
Purpose of control:	Pressure operating control
Features of automatic action:	Type 1.A
Degree of protection:	IP20 after mounted
Degree of pollution:	2
Ambient temperature limit of the switch head:	T55
Protection against electric shock:	Incorporated use, for class I or class II appliance
Circuit disconnection:	Full disconnection
Cycles of automatic action:	30 000
Operating pressure:	Max. 0.7MPa (7bar)
PTI:	175V

Tested according to: EN 60730-1:2016/A1:2019
 EN 60730-2-6:2016/A1:2020

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 874102107303-00

Date, 2021-06-30

(Jie Zhu)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.