



Product Service

Attestation of Conformity

No. N8A 111343 0010 Rev. 00

Holder of Attestation: **Zhejiang Lefoo Controls Co., Ltd**
No.220,Weishiwu Road.Economic Development Zone
325600 Yueqing, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: **Pressure switches**
Model(s): **LF58**

Parameters:

Rated voltage:	250VAC, 125VAC, 250VDC
Rated frequency:	50/60Hz for AC
Rated current:	10(10)A for 250VAC, 20(20)A for 125VAC, 0.05A for 250VDC
Features of automatic action:	Type 1.B
Type of disconnection:	Micro-disconnection
Degree of protection:	IP44
Degree of pollution:	2
Ambient temperature limit:	40T65
Number of cycles of automatic action:	30 000
Operating pressure:	Max. 4.5MPa
Protection against electric shock:	Incorporated in use, for class I appliance
PTI:	175

Tested according to: EN 60730-1:2016/A2:2022
EN 60730-2-6:2016/A1:2020

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 874102323503-00

Date, 2023-05-26

(Jie Zhu)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®