



Product Service

Attestation of Conformity

No. E8A 108521 0015 Rev. 00

Holder of Attestation: **Zhejiang LEFOO Sensing Technology Co.,Ltd.**

Building 3, NO.118 Changda Road, Linping Street
Linping District
311000 Hangzhou City, Zhejiang Province
PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Equipment for measurement & control
High accuracy temperature and humidity
transmitter**

Model(s): **LFH30 Series**

Description of Object:

Rated input:	9-35VDC/24VAC ± 20% (LFH301) 12-35VDC/24VAC ± 20% (LFH302) 12V+20mA*RL
Rated output:	RS485/0-10v/4-20mA

Tested according to: EN IEC 61000-6-1:2019
EN IEC 61000-6-3:2021

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 4842023237600

Date, 2023-04-17


(Ming Gu)

Page 1 of 1

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®