

Attestation of Conformity

No. N8AUK 111343 0005 Rev. 00

Holder of Certificate: **Zhejiang Lefoo Controls Co., Ltd**
No.220,Weishiwu Road.Economic Development Zone
325600 Yueqing, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: **Pressure switches**
Model(s): **LF16**

Parameters:

Rated voltage:	240VAC, 120VAC
Rated frequency:	50/60Hz
Rated current:	20A for 120VAC, 12A for 240VAC
Purpose of control:	Pressure operating control
Features of automatic action:	Type 1.A
Degree of protection:	IP20 after mounted
Degree of pollution:	2
Ambient temperature limit of the switch head:	T55
Protection against electric shock:	Incorporated use, for class I or class II appliance
Circuit disconnection:	Full disconnection
Cycles of automatic action:	30 000
Operating pressure:	Max. 0.7MPa (7bar)
PTI:	175V

Tested according to: EN 60730-1:2016/A1:2019
EN 60730-2-6:2016/A1:2020

This Attestation of Conformity is issued on a voluntary basis according to the Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the regulations and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 874102107305-00

Date, 2021-07-21



(Jie Zhu)