



China

Attestation of Conformity

No. N8AUK 111343 0004 Rev. 01

Holder of Attestation: Zhejiang Lefoo Controls Co., Ltd

No.220, Weishiwu Road. Economic Development Zone
325600 Yueqing, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product:

Pressure switches

Model(s):

LF19-1H, LF19-4H, LF19A-1H, LF19A-4H

Parameters:

Rated voltage:	250VAC, 120VAC
Rated frequency:	50/60Hz
Rated current:	16(10)A for 250VAC, 25(16)A for 120VAC
Features of automatic action:	Type 1.A
Type of disconnection:	Full disconnection
Degree of protection:	IP20 after mounted
Degree of pollution:	2
Ambient temperature limit:	T55
Number of cycles of automatic action:	30 000
Operating pressure:	Max. 1.4MPa (14bar)
Protection against electric shock:	Incorporated in use, for class I appliance
PTI:	175V

Tested according to:

EN 60730-1:2016/A2:2022
EN 60730-2-6:2016/A1:2020

This Attestation of Conformity is issued on a voluntary basis according to the Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the regulation and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment.

For details see: www.tuvsud.com/ps-cert

Test report no.: 874102107301-01

Date, 2023-07-12

(Hongbo Zhu)

Page 1 of 1

This Attestation does not replace the regulatory UK Declaration of Conformity (DoC) and does not allow for UKCA marking. After preparation of the necessary technical documentation and establishing compliance to requirements of all applicable regulations, the manufacturer may sign a DoC and apply the UKCA marking. The DoC is issued under the sole responsibility of the manufacturer.

**UK
CA**